

Smoke Ventilation Kit

DoP Ref:
K08/12101/13**EN 12101-10**Year of affixation:
10**1. Product Type:**

Keylite Budget Roof Window

2. Unique Identification Code(s):RZN 4503-T, RZN 43xx-E, RZN 4402-K V2, RZN 4404-K V2,
RZN 4402-KS V2, RZN 4404-KSV2, RZN 4404-M, RZN 4408-M, RZN
4408-K, RZN 4416-M, RZN 4404-MS, RZN 4408-MS, RZN 4408-KS**3. Manufacturer:**KEYLITE ROOF WINDOWS
Derryloran Industrial Est.
Sandholes Road, Cookstown
Co. Tyrone BT80 9LU**4. System of System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V of the CPR:**

System 1

5. Harmonised Standard:

EN 12101-10

6. Notified Body:

VdS Schadenverhütung GmbH - No. 786

7. Declared Performance:

Essential Characteristic	Performance	Harmonised Technical Specification
Operation reliability	Pass	EN 12101-10, 2005;
Performance parametes under fire conditions	Class A	
Environmental	Class 1	
Response class	$t \leq 1,5$ sec	

Smoke Ventilation Kit

DoP Ref:
K08/12101/13

EN 12101-10

Year of affixation:
10

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

Date:

01.08.2013

Signed:



Andy Neal

(Operations Director)